

ADDENDUM NO. 3  
WATER SYSTEM IMPROVEMENTS  
CONTRACT 15-01  
16-INCH NORTH WATER TRANSMISSION LINE – PHASE I  
OHIO COUNTY WATER DISTRICT  
OHIO COUNTY, KENTUCKY  
JRWCO JOB NO. 2021

Date of Addendum: Friday, March 25, 2016  
Bid Opening: Tuesday, March 29, 2016, 4:30 p.m. Local Time

1. Detailed Specifications, Section 4. Water Line and Appurtenances, Paragraph 3. Pipeline Materials for Water Lines, Subparagraph c. Polyvinyl Chloride (PVC) Pressure Pipe, Page DS 4-4:

Modify item (1) of this subparagraph as follows:

“(1) Materials, Manufacturer and Joints

Polyvinyl Chloride (PVC) Pressure Pipe shall conform to ANSI/AWWA Standard C-905 and shall be installed in accordance with ANSI/AWWA C-605 as amended or extended in these Specifications. The pipe shall be CI outside diameter in accordance with Table 2 of ANSI/AWWA C-905. PVC pipe shall be **blue** in color.

The following classes of pipe and pressure ratings are called for:

<u>Outside Diameter (in.)</u>	<u>Dimension Ration (DR)</u>	<u>Min. Wall Thickness</u>	<u>Pressure Class (psi)</u>
17.40	21	0.829	200”

J. R. WAUFORD & COMPANY,  
CONSULTING ENGINEERS, INC.



J. Gregory Davenport, P.E.  
Kentucky License No. 22752